



# MANTSOPA

## MUNICIPALITY

(Incorporating Ladybrand, Tweespruit, Excelsior, Hobhouse & Thaba Patchoa)  
(As from 6 December 2000)

### Head office

Private Bag X11 or  
P.O. Box 64  
LADYBRAND  
9745

38 Joubert Street  
LADYBRAND  
9745

Tel: 051-9240654  
051-9240659  
051-9240655  
051-9240657

Fax: 051-9240020

E-mail:  
[mantsopamun@xsinet.co.za](mailto:mantsopamun@xsinet.co.za)

### Area Offices

P.O. Box 76  
TWEESPRUIT  
9760

Tel: 051-9730015

Fax: 051-9730865

P.O. Box 24  
EXCELSIOR  
9760

Tel: 051-9730015

Fax: 051-9730865

P.O. Box 5  
HOBHOUSE  
9740

Tel: 051-9640012

Hobhouse Way 177

THABA PATCHOA  
9771

File no.:8/1/8/1

Contact Person: Khotso Pharoe

14 October 2025

RE-INVITATION FOR QUOTATIONS – SUPPLY, DELIVERY AND OFF-LOADING OF BULK METERS FOR  
MANTSOPA LOCAL MUNICIPALITY

### Specifications:

#### LADYBRAND

Location / Position	Size (mm)	Quantity	Working Pressure	Working Temperature	Protection Class
Genoa Big Clear Pump Station	250	1	PN16	0–50 °C (Cold potable water)	IP68
Low to High Pressure Reservoir Transfer Pipeline	300	1	PN16	0–50 °C (Cold potable water)	IP68
Special School Pipeline	50	1	PN16	0–50 °C (Cold potable water)	IP68
Town High Pressure 1 Old Pipeline	100	1	PN16	0–50 °C (Cold potable water)	IP68
Town High Pressure 2 New Pipeline	100	1	PN16	0–50 °C (Cold potable water)	IP68
Manyatseng Main Pipeline	200	1	PN16	0–50 °C (Cold potable water)	IP68

All correspondence to be addressed to the Municipal Manager

Tel: 051-9640012

Fax: 051-9640054

				water)	
Town Low Pressure Pipeline	150	1	PN16	0-50 °C (Cold potable water)	IP68

#### EXCELSIOR

Location / Position	Size (mm)	Quantity	Working Pressure	Working Temperature	Protection Class
Mahlatswetsa Reservoirs	110	3	PN16	0-50 °C (Cold potable water)	IP68
Town Reservoirs	110	2	PN16	0-50 °C (Cold potable water)	IP68

#### TWEESPRUIT

Location / Position	Size (mm)	Quantity	Working Pressure	Working Temperature	Protection Class
Bulkline and Reservoirs	90	5	PN16	0-50 °C (Cold potable water)	IP68

#### THABA PATCHOA

Location / Position	Size (mm)	Quantity	Working Pressure	Working Temperature	Protection Class
Bulkline and Reservoirs	100	1	PN16	0-50 °C (Cold potable water)	IP68

#### HOBHOUSE

Location / Position	Size (mm)	Quantity	Working Pressure	Working Temperature	Protection Class
Hobhouse WTW	200	1	PN16	0-50 °C (Cold potable water)	IP68
Reservoirs Inlet	150	3	PN16	0-50 °C (Cold potable water)	IP68

### Specified Goals for Preferential Points System

Specific Goals	Points Allocation
Black Owned (More than 51%)	10
Women owned (More than %51%)	5
Youth Owned <35(More than 51%)	5
Total Points	20

Enquiries on Specification: Mr. Thabo Ketime (060 507 5083)

Quotations must be submitted and delivered to the Quotation Box (telephone number: 051 924 0654) at 38 Joubert Street, Ladybrand 9745, on or before 24 October 2025 @12h00 the envelope must be sealed and clearly marked 'SUPPLY, DELIVERY AND OFF-LOADING OF BULK METERS FOR MANTSOPA LOCAL MUNICIPALITY" quoting reference number SCM/WD 10/25/26


RECOMMENDATION BY THE CFO:



TSHIKUNDU

DATE: 14/10/2025

APPROVAL BY THE MM



MQGOPODI

MUNICIPAL MANAGER

DATE: 14/10/2025

